

TEST CERTIFICATE

Code	916319
Serial Number	2862149
Voltage	400V 3N 50Hz 5,55kW
Customer Code	DC502/PS-NP
Date of issue	08/04/2016 14:29:56

3K

Earth Continuity Test		OK	
Resistance Max	0,100 ohm	Current Min	25,000 A
Resistance Meas.	0,050 ohm	Current Meas.	31,103 A
Insulation 3P		OK	
Resistance Min	2,0 MOhm	Resistance Meas. Ph. R	100,0 MOhm
Resistance Meas. Ph. N	100,0 MOhm	Resistance Meas. Ph. S	100,0 MOhm
Resistance Meas. Ph. T	100,0 MOhm	Voltage Meas.	503,1 V
Electric Strength 3P		OK	
Voltage	1000 V	Current Max	10,00 mA
Current Meas. Ph. R	0,03 mA	Current Meas. Ph. N	0,00 mA
Current Meas. Ph. S	0,03 mA	Current Meas. Ph. T	0,03 mA
Insulation 3P		OK	
Resistance Min	2,0 MOhm	Resistance Meas. Ph. R	100,0 MOhm
Resistance Meas. Ph. N	100,0 MOhm	Resistance Meas. Ph. S	100,0 MOhm
Resistance Meas. Ph. T	100,0 MOhm	Voltage Meas.	503,1 V
Electric Strength 3P		OK	
Voltage	1000 V	Current Max	10,00 mA
Current Meas. Ph. R	0,17 mA	Current Meas. Ph. N	0,03 mA
Current Meas. Ph. S	0,48 mA	Current Meas. Ph. T	0,14 mA
Leakage Current 3P		OK	
Voltage	424 V	Current Max	5,00 mA
Current Meas. Ph. R	0,94 mA	Current Meas. Ph. N	0,04 mA
Current Meas. Ph. S	0,90 mA	Current Meas. Ph. T	0,94 mA